

ANSUL PART NO. 17633) MUST ALWAYS BE INTERFERE OVER THE STEAM
REPLACE FILL CAP TIGHTLY REPLACE CYLINDER IF PRESSURE IS LESS
THAN 103.4 BAR (1500 PSI) AT 21 °C (70 °F) FOR DETAILED RECHARGE
INSTRUCTIONS REFER TO ANSUL ASSEMBLY OPERATION RECHARGE
INSPECTION AND MAINTENANCE MANUAL PART NO. 79012 OR
CONTACT YOUR AUTHORIZED ANSUL DISTRIBUTOR FOR SERVICE



LISTED

CLASSIFICATION 40-A, 240-B, C

12570

NO.

40-02-008

RATED WITH NO. 25 NOZZLE TIP

SUITABLE FOR USE AT TEMPERATURES FROM -54
(-65 °F TO +120 °F)

ANSUL INCORPORATED (INC. STATION)

#48



#48